

(4)

FOUNDATION™

DEVICE REGISTRATION

Manufacturer: Microcyber Inc.

Model: NCS-IF105

Type: 4-20 mA to Fieldbus Converter

Device ITK Version: 5.0.1
Device Test Campaign: IT056200

Test Report: FF-527-(56200)

Stack Test Campaign: CT0076FF
Physical Layer Test Report: PT-279

Manufacturer ID: 0x000105
Device Type: 0x0001
Device Revision: 0x01

	Filename	CRC	ITK Version
Device Description:	0101.ffa	7CC4B577	5.0.1
	0101.sym	14321EAC	5.0.1


Capability File:	010101.cff	6F6B63DB	5.0.1
-------------------------	------------	----------	-------

Tested Features:

- Alarms and Events
- Trending
- Function Block Linking
- Block Instantiation
- Resource Block
- Analog Input Function Blocks
- PID Control Function Block
- Input Selector Function Block
- Signal Characterizer Function Block

17 September 2008

Registration Date



Richard J. Timoney
President and CEO