

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

Microcyber Corporation

17-8 Wensu Street, Hunnan New District, 110179 Shenyang, China

the Certificate No: **Z02361** for the PROFIBUS Device:

Model Name: NCS-TT105P
Revision: 04.00; SW/FW: 01.00; HW: 1.0
GSD: MCYB11AD.GSD, File Version: 5.0
pa139703.GSD

This certificate confirms that the product has successfully passed the certification tests with the following scope:

☒ DP-V0	MS0, Set_Slave_Add, Fail_Safe
☒ DP-V1	MS1, MS2, Prm_Block_Structure, Ext_Prm_SAP, I&M
☒ Profile	PROFIBUS PA 3.02
☒ Physical Layer	MBP

Test Report Number: MCDL-2023-4078-D
Authorized Test Laboratory: ITEI, Beijing, China

The tests were executed in accordance with the following documents:
"Test Specifications for PROFIBUS DP Slaves, Version 3.0.9, September 2008" and
"Test Specifications for PROFIBUS PA Profile 3.0.2, Version 5.0.4, February 2010".

This certificate is granted according to the document:
"Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by **March 05, 2027** the certificate is valid for life.

Karlsruhe, June 17, 2024

Board of PROFIBUS Nutzerorganisation e. V.



(Official in Charge)



(Xaver Schmidt)



(Frank Moritz)