



EXPLOSION PROTECTION

CERTIFICATE OF CONFORMITY

Cert No. GYB24.3207X

Manufacturer	Microcyber Corporation (Address:17-8 Wensu Street, Hunnan New District, Shenyang.)
Product	Mult-channel temperature transmitter
Model	NCS-TT108a-IC-c
Ex marking	Ex ia IIC T4 Ga
Product standard	Q/BW02-2024
Drawing number	NCS-TT108-00

The product was found to comply with the following standard(s):

GB/T 3836.1-2021,GB/T 3836.4-2021

Valid until: 2029.12.02

Remarks

- 1.Conditions for safe use are specified in the instructions.
- 2.Symbol "X" placed after the certification number denotes specific conditions of use, which are specified in the attachment to this certificate.
- 3.Intrinsic safety parameters specified in the attachment to this certificate.

Approval

Shanghai Inspection and Testing Institute of
Instruments and Automation Systems Co., Ltd.
National Supervision and Inspection Center for
Explosion Protection and Safety of Instrumentation
Date of issue 2024.12.03

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.