

CERTIFICATE

Registered No.:
CER-IND1102822502002001

Valid until
26th August, 2030

Assessment report No.
CR-IND1102822502002001

Date of issue
27th August, 2025

Revision
A

This is to certify that the following product complies with the relevant requirements of the mentioned safety standards:

Applicant: MICROCYBER CORPORATION
Floor 1-3, 1#, NO.17-8, Wensu Street, Hunnan New District,
Shenyang City Liaoning Province, P.R.China

Product: Intelligent Temperature Transmitter
Model: NCS-TT306H series

Scope: IEC61508: 2010, (Parts 1~3)

Result: The safety functions: NCS-TT306H series Temperature Transmitter convert sensor input signals from hazardous areas to a 4~20mA current output signal, fulfil the SIL2 (HFT=0) and SIL3 (HFT=1) requirements of the standard.

Remark: The device must be properly integrated into the Safety Instrumented Function (SIF) as defined in the Safety Manual. PFH/PFD_{avg} and architecture constraints must be verified for each application. To fulfill all parameters specified in the appendix, users shall perform periodic inspections and maintenance in accordance with the inspection and validation testing requirements stipulated in the Safety Manual. The certificate is issued based on an evaluation conducted in compliance with the currently effective version of the certification rule TNH-Z-IND-CR-005.2 and the assessment report.


Mr. Andy Zheng
Name and Signature


Issued at Shanghai
Place, Stamp



APPENDIX

of certificate No.: CER-IND1102822502002001

Page 1 of 1

Valid until
26th August, 2030

Assessment report No.
CR-IND1102822502002001

Date of issue
27th August, 2025

Revision
A

Product	Intelligent Temperature Transmitter		
Models	NCS-TT306HHICC-SL, NCS-TT306HHICN-SL, NCS-TT306HH1ICC-SL, NCS-TT306HH1ICN-SL, NCS-TT306HHNAC-SL, NCS-TT306HHNAN-SL, NCS-TT306HH1NAC-SL, NCS-TT306HH1NAN-SL, NCS-TT306HRIC-SL, NCS-TT306HR1IC-SL, NCS-TT306HRINA-SL, NCS-TT306HR1NA-SL		
Specific of product	Systematic Capability	SC 3	
	Type of Product	B	
	Route of Assessment	1 _H	
	SFF (Safe Failure Fraction)	91.03 %	
	λ_s (Safe Failure Rate)	7.71E-08 /h	77.1 FIT
	λ_{du} (Dangerous Undetected Failure Rate)	2.32E-08 /h	23.2 FIT
	λ_{dd} (Dangerous Detected Failure Rate)	1.52E-07 /h	152.3 FIT
	T1 (Proof test intervals)	43800 Hours (5 Years)	
	PFD_{avg} @ 1oo1(HFT=0) (Average Probability of dangerous Failure on Demand)	5.137E-04	
	PFD_{avg} @ 1oo2(HFT=1) (Average Probability of dangerous Failure on Demand)	1.058E-05	
	PFH @ 1oo1(HFT=0) (Average frequency of dangerous Failure [h ⁻¹])	2.326E-08	
	PFH @ 1oo2(HFT=1) (Average frequency of dangerous Failure [h ⁻¹])	4.89E-10	

证书

证书编号:

CER-IND1102822502002001

有效期至:
2030 年 08 月 26 日评估报告编号:
CR-IND1102822502002001发证日期:
2025 年 08 月 27 日版本:
A

经评估, 以下产品符合适用的标准条款的要求:

客户名称: 沈阳中科博微科技股份有限公司
沈阳市浑南新区文溯街 17-8 号 1 号楼 1-3 层

产品名称: 智能温度变送器

产品型号: NCS-TT306H 系列

范围: IEC61508:2010, (1~3 部分)

结论: 安全功能: NCS-TT306H 系列智能温度变送器能够将来自危险区域的传感器输入信号转换成 4-20mA 电流输出信号, 符合 SIL2 (HFT=0) SIL3 (HFT=1)的安全要求。

注意事项及限制: 该装置必须根据《安全手册》中的要求, 正确集成到安全仪表功能中, PFH/PFDavg 与架构约束必须针对每项应用进行验证。为满足附录中的各项参数, 用户须按照《安全手册》规定的检查与验证测试要求, 定期进行检查和维护。本证书是依据认证规则 TNH-Z-IND-CR-005.2 的现行有效版本和评估报告进行的评估签发。


姓名和签署

附录

证书编号: CER-IND1102822502002001

有效期至： 2030 年 08 月 26 日		评估报告编号： CR-IND1102822502002001		发证日期： 2025 年 08 月 27 日		版本： A	
产品名称		智能温度变送器					
产品型号		NCS-TT306HHICC-SL, NCS-TT306HHICN-SL, NCS-TT306HH1ICC-SL, NCS-TT306HH1ICN-SL, NCS-TT306HHNAC-SL, NCS-TT306HHNAN-SL, NCS-TT306HH1NAC-SL, NCS-TT306HH1NAN-SL, NCS-TT306HRIC-SL, NCS-TT306HR1IC-SL, NCS-TT306HRINA-SL, NCS-TT306HR1NA-SL					
具体参数		系统能力			SC 3		
		产品类型			B		
		评估路线			1 _H		
		安全失效分数 (SFF)			91.03%		
		安全失效率 (λ _s)			7.71E-08 /h		77.1 FIT
		未检测到的危险失效率 (λ _{du})			2.33E-08 /h		23.3 FIT
		被检测到的危险失效率 (λ _{dd})			1.52E-07 /h		152.3 FIT
		检验测试时间间隔 (T1)			43800小时 (5 年)		
		要求时危险失效平均概率 (PFD _{avg}) —1oo1(HFT=0)			5.137E-04		
		要求时危险失效平均概率 (PFD _{avg}) —1oo2(HFT=1)			1.058E-05		
		每小时危险失效平均频率 (PFH) —1oo1(HFT=0)			2.326E-08		
		每小时危险失效平均频率 (PFH) —1oo2(HFT=1)			4.89E-10		