



Device Registration

Manufacturer	Microcyber Corporation 17-8 Wensu Street, Hunnan New District Shenyang, Liaoning 110179 China	
Model Type	NCS-PT105 Pressure Transmitter	
H1 ITK Profile	6	
Manufacturer Identification (MANUFAC_ID)	0x000105	
Device Type (DEV_TYPE)	0x0003	
Device Revision (DEV_REV)	0x03	
Stack Communication Profiles	31PS, 32L	
H1 Physical Layer Profiles	113	
Device Test Campaign	IT127800	
Stack Test Campaign	CT0076FF	
H1 Physical Layer Test Report	PT-623	
Electronic Device Descriptions	0301.FFO	(CRC: 0x80840A7F)
	0301.SYM	(CRC: 0x0A82602E)
	0301.FF5	(CRC: 0xB32EC241)
	0301.SY5	(CRC: 0x0A82602E)
Capability File	030101.CFF	(CRC: 0x8A13686F)
Mandatory Features	Resource Block Alarms and Events Function Block Linking Trending Multi-Bit Alert Reporting Field Diagnostics	
Function Blocks	Analog Input Proportional Integral Derivative Arithmetic Input Selector Integrator Signal Characterizer	
Registration Number	IT/127800/1	
Registration Program	FCG-PD10026 REV 1.0 / FF-524 REV 2.11	
Date Issued	2021-09-09	

**Authorized
Mark**

Use of mark subject to
Graphic Identify Style Guide



Ted Masters
President and Chief Executive Officer